



June 27, 2024

William Kotas
Intertek PSI
17 British American Boulevard
Latham, NY 12110

RE: Project: BETHLEHEM CSD 6/12
Pace Project No.: 70301179

Dear William Kotas:

Enclosed are the analytical results for sample(s) received by the laboratory on June 13, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Betty Harrison for
Lori A. Beyer
lori.beyer@pacelabs.com
516-370-6014
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Virginia Certification # 460302

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**SAMPLE SUMMARY**

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70301179001	181	Drinking Water	06/12/24 05:06	06/13/24 08:00
70301179002	182	Drinking Water	06/12/24 05:07	06/13/24 08:00
70301179003	186	Drinking Water	06/12/24 05:11	06/13/24 08:00
70301179004	188	Drinking Water	06/12/24 05:13	06/13/24 08:00
70301179005	189	Drinking Water	06/12/24 05:15	06/13/24 08:00
70301179006	190	Drinking Water	06/12/24 05:19	06/13/24 08:00
70301179007	191	Drinking Water	06/12/24 05:19	06/13/24 08:00
70301179008	192	Drinking Water	06/12/24 05:17	06/13/24 08:00
70301179009	194	Drinking Water	06/12/24 05:23	06/13/24 08:00
70301179010	196	Drinking Water	06/12/24 05:27	06/13/24 08:00
70301179011	197	Drinking Water	06/12/24 05:29	06/13/24 08:00
70301179012	198	Drinking Water	06/12/24 05:30	06/13/24 08:00
70301179013	199	Drinking Water	06/12/24 05:33	06/13/24 08:00
70301179014	200	Drinking Water	06/12/24 05:35	06/13/24 08:00
70301179015	201	Drinking Water	06/12/24 05:32	06/13/24 08:00
70301179016	202	Drinking Water	06/12/24 05:54	06/13/24 08:00
70301179017	203	Drinking Water	06/12/24 05:38	06/13/24 08:00
70301179018	204	Drinking Water	06/12/24 05:39	06/13/24 08:00
70301179019	206	Drinking Water	06/12/24 05:43	06/13/24 08:00
70301179020	209	Drinking Water	06/12/24 05:45	06/13/24 08:00
70301179021	210	Drinking Water	06/12/24 05:49	06/13/24 08:00
70301179022	211	Drinking Water	06/12/24 05:49	06/13/24 08:00
70301179023	212	Drinking Water	06/12/24 05:56	06/13/24 08:00
70301179024	216	Drinking Water	06/12/24 06:00	06/13/24 08:00
70301179025	217	Drinking Water	06/12/24 06:02	06/13/24 08:00
70301179026	218	Drinking Water	06/12/24 06:03	06/13/24 08:00
70301179027	219	Drinking Water	06/12/24 06:03	06/13/24 08:00
70301179028	220	Drinking Water	06/12/24 06:06	06/13/24 08:00
70301179029	221	Drinking Water	06/12/24 06:08	06/13/24 08:00
70301179030	222	Drinking Water	06/12/24 06:06	06/13/24 08:00
70301179031	223	Drinking Water	06/12/24 06:07	06/13/24 08:00
70301179032	224	Drinking Water	06/12/24 06:07	06/13/24 08:00
70301179033	225	Drinking Water	06/12/24 06:09	06/13/24 08:00
70301179034	226	Drinking Water	06/12/24 06:10	06/13/24 08:00
70301179035	231	Drinking Water	06/12/24 06:41	06/13/24 08:00
70301179036	232	Drinking Water	06/12/24 06:24	06/13/24 08:00
70301179037	233	Drinking Water	06/12/24 06:29	06/13/24 08:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70301179038	234	Drinking Water	06/12/24 06:32	06/13/24 08:00
70301179039	235	Drinking Water	06/12/24 06:33	06/13/24 08:00
70301179040	236	Drinking Water	06/12/24 06:20	06/13/24 08:00
70301179041	237	Drinking Water	06/12/24 06:21	06/13/24 08:00
70301179042	238	Drinking Water	06/12/24 06:37	06/13/24 08:00
70301179043	241	Drinking Water	06/12/24 05:41	06/13/24 08:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70301179001	181	EPA 200.8	JP2	1
70301179002	182	EPA 200.8	JP2	1
70301179003	186	EPA 200.8	JP2	1
70301179004	188	EPA 200.8	JP2	1
70301179005	189	EPA 200.8	JP2	1
70301179006	190	EPA 200.8	JP2	1
70301179007	191	EPA 200.8	JP2	1
70301179008	192	EPA 200.8	JP2	1
70301179009	194	EPA 200.8	JP2	1
70301179010	196	EPA 200.8	JP2	1
70301179011	197	EPA 200.8	JP2	1
70301179012	198	EPA 200.8	JP2	1
70301179013	199	EPA 200.8	JP2	1
70301179014	200	EPA 200.8	JP2	1
70301179015	201	EPA 200.8	JP2	1
70301179016	202	EPA 200.8	JP2	1
70301179017	203	EPA 200.8	JP2	1
70301179018	204	EPA 200.8	JP2	1
70301179019	206	EPA 200.8	JP2	1
70301179020	209	EPA 200.8	JP2	1
70301179021	210	EPA 200.8	JP2	1
70301179022	211	EPA 200.8	JP2	1
70301179023	212	EPA 200.8	JP2	1
70301179024	216	EPA 200.8	JP2	1
70301179025	217	EPA 200.8	JP2	1
70301179026	218	EPA 200.8	JP2	1
70301179027	219	EPA 200.8	JP2	1
70301179028	220	EPA 200.8	JP2	1
70301179029	221	EPA 200.8	JP2	1
70301179030	222	EPA 200.8	JP2	1
70301179031	223	EPA 200.8	JP2	1
70301179032	224	EPA 200.8	JP2	1
70301179033	225	EPA 200.8	JP2	1
70301179034	226	EPA 200.8	JP2	1
70301179035	231	EPA 200.8	JP2	1
70301179036	232	EPA 200.8	JP2	1
70301179037	233	EPA 200.8	JP2	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70301179038	234	EPA 200.8	JP2	1
70301179039	235	EPA 200.8	JP2	1
70301179040	236	EPA 200.8	JP2	1
70301179041	237	EPA 200.8	JP2	1
70301179042	238	EPA 200.8	JP2	1
70301179043	241	EPA 200.8	JP2	1

PACE-MV = Pace Analytical Services - Melville

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 181		Lab ID: 70301179001	Collected: 06/12/24 05:06	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.3	ug/L	1.0	1		06/21/24 13:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 182		Lab ID: 70301179002	Collected: 06/12/24 05:07	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 186		Lab ID: 70301179003	Collected: 06/12/24 05:11	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 188		Lab ID: 70301179004	Collected: 06/12/24 05:13	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 189		Lab ID: 70301179005	Collected: 06/12/24 05:15	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 190		Lab ID: 70301179006	Collected: 06/12/24 05:19	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 191		Lab ID: 70301179007	Collected: 06/12/24 05:19	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 192		Lab ID: 70301179008	Collected: 06/12/24 05:17	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 194		Lab ID: 70301179009		Collected: 06/12/24 05:23		Received: 06/13/24 08:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/21/24 13:38	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 196		Lab ID: 70301179010	Collected: 06/12/24 05:27	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 197		Lab ID: 70301179011	Collected: 06/12/24 05:29	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 198		Lab ID: 70301179012	Collected: 06/12/24 05:30	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 199		Lab ID: 70301179013	Collected: 06/12/24 05:33	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.2	ug/L	1.0	1		06/21/24 13:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 200		Lab ID: 70301179014		Collected: 06/12/24 05:35	Received: 06/13/24 08:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 201		Lab ID: 70301179015	Collected: 06/12/24 05:32	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 202		Lab ID: 70301179016		Collected: 06/12/24 05:54	Received: 06/13/24 08:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 203		Lab ID: 70301179017	Collected: 06/12/24 05:38	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.8	ug/L	1.0	1		06/21/24 13:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 204		Lab ID: 70301179018	Collected: 06/12/24 05:39	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.2	ug/L	1.0	1		06/21/24 13:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 206		Lab ID: 70301179019	Collected: 06/12/24 05:43	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.7	ug/L	1.0	1		06/21/24 13:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 209		Lab ID: 70301179020		Collected: 06/12/24 05:45	Received: 06/13/24 08:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 13:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 210		Lab ID: 70301179021	Collected: 06/12/24 05:49	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 211		Lab ID: 70301179022	Collected: 06/12/24 05:49	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 212		Lab ID: 70301179023	Collected: 06/12/24 05:56	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 216		Lab ID: 70301179024	Collected: 06/12/24 06:00	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 217		Lab ID: 70301179025	Collected: 06/12/24 06:02	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 218		Lab ID: 70301179026	Collected: 06/12/24 06:03	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 219		Lab ID: 70301179027		Collected: 06/12/24 06:03	Received: 06/13/24 08:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 220		Lab ID: 70301179028		Collected: 06/12/24 06:06	Received: 06/13/24 08:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 221		Lab ID: 70301179029		Collected: 06/12/24 06:08	Received: 06/13/24 08:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		06/21/24 14:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 222		Lab ID: 70301179030	Collected: 06/12/24 06:06	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 223		Lab ID: 70301179031	Collected: 06/12/24 06:07	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 224		Lab ID: 70301179032		Collected: 06/12/24 06:07	Received: 06/13/24 08:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 225		Lab ID: 70301179033	Collected: 06/12/24 06:09	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.2	ug/L	1.0	1		06/21/24 14:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 226		Lab ID: 70301179034	Collected: 06/12/24 06:10	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	30.7	ug/L	1.0	1		06/21/24 14:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 231		Lab ID: 70301179035		Collected: 06/12/24 06:41	Received: 06/13/24 08:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		06/21/24 14:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 232		Lab ID: 70301179036		Collected: 06/12/24 06:24	Received: 06/13/24 08:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 233		Lab ID: 70301179037		Collected: 06/12/24 06:29	Received: 06/13/24 08:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.4	ug/L	1.0	1		06/21/24 14:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 234		Lab ID: 70301179038	Collected: 06/12/24 06:32	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 235		Lab ID: 70301179039		Collected: 06/12/24 06:33	Received: 06/13/24 08:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.6	ug/L	1.0	1		06/21/24 14:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 236		Lab ID: 70301179040	Collected: 06/12/24 06:20	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.9	ug/L	1.0	1		06/21/24 14:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 237		Lab ID: 70301179041	Collected: 06/12/24 06:21	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		06/21/24 14:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 238		Lab ID: 70301179042	Collected: 06/12/24 06:37	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.5	ug/L	1.0	1		06/21/24 14:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Sample: 241		Lab ID: 70301179043	Collected: 06/12/24 05:41	Received: 06/13/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		06/21/24 14:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

QC Batch:	352631	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70301179001, 70301179002, 70301179003

METHOD BLANK: 1826760 Matrix: Water

Associated Lab Samples: 70301179001, 70301179002, 70301179003

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/21/24 12:26	

LABORATORY CONTROL SAMPLE: 1826761

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.6	103	85-115	

MATRIX SPIKE SAMPLE: 1826763

Parameter	Units	70301295021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	43.8	87	70-130	

MATRIX SPIKE SAMPLE: 1826765

Parameter	Units	70301295022 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	53.6	106	70-130	

SAMPLE DUPLICATE: 1826762

Parameter	Units	70301295021 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

SAMPLE DUPLICATE: 1826764

Parameter	Units	70301295022 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

QC Batch:	352632	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70301179004, 70301179005, 70301179006, 70301179007, 70301179008, 70301179009, 70301179010, 70301179011, 70301179012, 70301179013, 70301179014, 70301179015, 70301179016, 70301179017, 70301179018, 70301179019, 70301179020, 70301179021, 70301179022, 70301179023		

METHOD BLANK:	1826766	Matrix:	Water
Associated Lab Samples:	70301179004, 70301179005, 70301179006, 70301179007, 70301179008, 70301179009, 70301179010, 70301179011, 70301179012, 70301179013, 70301179014, 70301179015, 70301179016, 70301179017, 70301179018, 70301179019, 70301179020, 70301179021, 70301179022, 70301179023		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/21/24 13:17	

LABORATORY CONTROL SAMPLE:	1826767					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.0	102	85-115	

MATRIX SPIKE SAMPLE:	1826769						
Parameter	Units	70301179004 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	42.0	83	70-130	

MATRIX SPIKE SAMPLE:	1826771						
Parameter	Units	70301179005 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	44.6	89	70-130	

SAMPLE DUPLICATE:	1826768					
Parameter	Units	70301179004 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

SAMPLE DUPLICATE:	1826770					
Parameter	Units	70301179005 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

QC Batch:	352633	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70301179024, 70301179025, 70301179026, 70301179027, 70301179028, 70301179029, 70301179030, 70301179031, 70301179032, 70301179033, 70301179034, 70301179035, 70301179036, 70301179037, 70301179038, 70301179039, 70301179040, 70301179041, 70301179042, 70301179043		

METHOD BLANK:	1826772	Matrix:	Water
Associated Lab Samples:	70301179024, 70301179025, 70301179026, 70301179027, 70301179028, 70301179029, 70301179030, 70301179031, 70301179032, 70301179033, 70301179034, 70301179035, 70301179036, 70301179037, 70301179038, 70301179039, 70301179040, 70301179041, 70301179042, 70301179043		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/21/24 14:10	

LABORATORY CONTROL SAMPLE:	1826773					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.5	103	85-115	

MATRIX SPIKE SAMPLE:	1826775						
Parameter	Units	70301179024 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	39.3	77	70-130	

MATRIX SPIKE SAMPLE:	1826777						
Parameter	Units	70301179025 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.1	96	70-130	

SAMPLE DUPLICATE:	1826774					
Parameter	Units	70301179024 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

SAMPLE DUPLICATE:	1826776					
Parameter	Units	70301179025 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: BETHLEHEM CSD 6/12

Pace Project No.: 70301179

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70301179001	181	EPA 200.8	352631		
70301179002	182	EPA 200.8	352631		
70301179003	186	EPA 200.8	352631		
70301179004	188	EPA 200.8	352632		
70301179005	189	EPA 200.8	352632		
70301179006	190	EPA 200.8	352632		
70301179007	191	EPA 200.8	352632		
70301179008	192	EPA 200.8	352632		
70301179009	194	EPA 200.8	352632		
70301179010	196	EPA 200.8	352632		
70301179011	197	EPA 200.8	352632		
70301179012	198	EPA 200.8	352632		
70301179013	199	EPA 200.8	352632		
70301179014	200	EPA 200.8	352632		
70301179015	201	EPA 200.8	352632		
70301179016	202	EPA 200.8	352632		
70301179017	203	EPA 200.8	352632		
70301179018	204	EPA 200.8	352632		
70301179019	206	EPA 200.8	352632		
70301179020	209	EPA 200.8	352632		
70301179021	210	EPA 200.8	352632		
70301179022	211	EPA 200.8	352632		
70301179023	212	EPA 200.8	352632		
70301179024	216	EPA 200.8	352633		
70301179025	217	EPA 200.8	352633		
70301179026	218	EPA 200.8	352633		
70301179027	219	EPA 200.8	352633		
70301179028	220	EPA 200.8	352633		
70301179029	221	EPA 200.8	352633		
70301179030	222	EPA 200.8	352633		
70301179031	223	EPA 200.8	352633		
70301179032	224	EPA 200.8	352633		
70301179033	225	EPA 200.8	352633		
70301179034	226	EPA 200.8	352633		
70301179035	231	EPA 200.8	352633		
70301179036	232	EPA 200.8	352633		
70301179037	233	EPA 200.8	352633		
70301179038	234	EPA 200.8	352633		
70301179039	235	EPA 200.8	352633		
70301179040	236	EPA 200.8	352633		
70301179041	237	EPA 200.8	352633		
70301179042	238	EPA 200.8	352633		
70301179043	241	EPA 200.8	352633		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



CHAIN-OF-CUSTODY Analytical Request Document
 Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Pace® Location Requested (City/State): Pace Analytical Long Island NY
 575 Broad Hollow Rd, Melville, NY 11747

Company Name: Intertek-PSI
Street Address: 17 British American Blvd, Latham, NY 12210

Customer Project #: 08215496
Project Name: Bethlehem CSD

Contact/Report To: William Kotas
 Phone #: (518) 377-9841
 E-Mail: william.kotas@intertek.com
 Cc E-Mail:

Invoice To: PSI Latham Accounts Payable
Invoice E-Mail: LathamAR@intertek.com

Purchase Order # (if applicable):
Quote #: CR-BOCES

County / State origin of sample(s): New York

Regulatory Program (DW, RCHA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
 DW PWSID # or WW Permit # as applicable:
 Field Filtered (if applicable): [] Yes [] No
 Analysis:
 Date Results Requested: Standard 10 business day

Site Collection Info/Facility ID (as applicable):
 High School

Time Zone Collected: [] AK [] PT [] MT [] CT [X] ET

Data Deliverables:
 [] Level II [] Level III [] Level IV
 [] EQUIS
 [] Other

Customer Sample ID	Matrix *	Comp / Grab	Collected		Res. CLZ	Number & Type of Containers	Preservation non-conformance identified for sample
			Date	Time			
181	DW	G	6/12/24	5:06		1	
182			6/12/24	5:07			
185			6/12/24	5:11			
188			6/12/24	5:13			
189			6/12/24	5:15			
190			6/12/24	5:19			
191			6/12/24	5:19			
192			6/12/24	5:17			
194			6/12/24	5:23			
196			6/12/24	5:27			

Additional Instructions from Pace®:

Collected By: Richard Paszkiewicz
Signature: *[Signature]*

Received by/Company (Signature): *[Signature]*
Date/Time: 6/12/24 9:15

Received by/Company (Signature): *[Signature]*
Date/Time: 6/12/24 9:27

Received by/Company (Signature): *[Signature]*
Date/Time: 6/13 8:00

Received by/Company (Signature): *[Signature]*
Date/Time: 6/13 8:00

Tracking Number: 2014 201
Thermometer ID: T4711
Correction Factor (°C): -0.1
Obs. Temp. (°C): 20.6
Corrected Temp. (°C): 20.6

Date/Time: 6/12/24 9:15
Date/Time: 6/13 4:10
Date/Time: 6/13/27 8:00

Delivered by: [] In-Person [X] Courier
 [] FedEx [] UPS [] Other

Page: 1 of 5

Customer Remarks / Special Conditions / Possible Hazards:

Lead

Relinquished by/Company (Signature): *[Signature]*
Date/Time: 6/12/24 9:15

Relinquished by/Company (Signature): *[Signature]*
Date/Time: 6/12/24 9:27

Relinquished by/Company (Signature): *[Signature]*
Date/Time: 6/13 8:00

Relinquished by/Company (Signature): *[Signature]*
Date/Time: 6/13 8:00



LAB USE ONLY - Affix Workorder/Login Label Here

Scan QR Code for instructions

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

CHAIN-OF-CUSTODY Analytical Request Document

Pace® Location Requested (City/State): Pace Analytical Long Island NY
 575 Broad Hollow Rd, Melville, NY 11747

Company Name: Intertek-PSI
 Street Address: 17 British American Blvd, Latham, NY 12210

Contact/Report To: William Kotas
 Phone #: (518) 377-9841
 E-Mail: william.kotas@intertek.com
 Cc E-Mail:

Customer Project #: 08215496
 Project Name: Bethlehem CSD

Site Collection Info/Facility ID (as applicable):
 High School

Time Zone Collected: [] AK [] PT [] MT [] CT [X] ET [] AT

Data Deliverables:
 () Level II () Level III () Level IV
 () EQUIS
 () Other: _____

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
 () 2 Day () 3 day () 5 day () Other: _____
 Date Results Requested: Standard 10 business day
 Field Filtered (if applicable): [] Yes [] No
 Analysis:

Country / State origin of sample(s): New York

Specify Container Size **

Identify Container Preservative Type**

Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Proj. Mgr: Lori Beyer
 AcctNum / Client ID:
 Table #:
 Profile / Template:
 10367
 Preg / Bottle Ord. ID:

Lab Use Only

Preservation non-performance identified for sample:

Customer Sample ID	Matrix *	Comp / Grab	Collected		Composite End		Res. CL2	Number & Type of Containers		Sample Comment
			Date	Time	Date	Time		Plastic	Glass	
197	DW	G	6/12/24	529				1		X
198			6/12/24	530						
199			6/12/24	533						
200			6/12/24	535						
201			6/12/24	532						
202			6/12/24	554						
203			6/12/24	536						
204			6/12/24	539						
205			6/12/24	543						
209			6/12/24	545						

Customer Remarks / Special Conditions / Possible Hazards:
 Lead

Collected By: Richard Paszkiewicz
 Printed Name: Richard Paszkiewicz
 Signature: *[Signature]*

Coolers: 1
 Thermometer ID: TH200
 Correction Factor (°C): -0.1
 Obs. Temp (°C): 20.6
 Corrected Temp. (°C): 20.7

Date/Time: 6/12/24 9:15
 Date/Time: 6/12/24 9:22
 Date/Time: 6/13/24 8:00

Received by/Company (Signature): *[Signature]*
 Received by/Company (Signature): *[Signature]*
 Received by/Company (Signature): *[Signature]*

Delivered by: [] In-Person [X] Courier
 [] FedEx [] UPS [] Other

Page: 2 of 5



LAB USE ONLY - Affix Workorder/Login Label Here

Scan QR Code for instructions

Chain-of-Custody Analytical Request Document
 Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Pace®
 Pace Analytical Long Island NY
 575 Broad Hollow Rd, Melville, NY 11747

Company Name: Intertek-PSI
Street Address: 17 British American Blvd, Latham, NY 12120
Customer Project #: 08215496
Project Name: Bethlehem CSD

Contact/Report To: William Kotas
Phone #: (518) 377-9841
E-Mail: william.kotas@intertek.com
Cc E-Mail:

Invoice To: PSI Latham Accounts Payable
Invoice E-Mail: LathamAR@intertek.com
Purchase Order # (if applicable):
Quote #: CR-BOCES

Time Zone Collected: [] AK [] PT [] MT [] CT [X] ET
Data Deliverables:
 [] Level II [] Level III [] Level IV
 [] EQUIS
 [] Other _____

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW
County / State origin of sample(s): New York

Rush (Pre-approval required):
 [] 2 Day [] 3 day [] 5 day [] Other _____
Date Results Requested: Standard 10 business day

Site Collection Info/Facility ID (as applicable):
 High School

Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Specify Container Size **
 *** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) NaOH, (11) Other

Identify Container Preservative Type***
 Analysis Requested

Proj. Mgr: Lori Beyer
AcctNum / Client ID:
Table #:
Profile / Template: 10367
Prelog / Bottle Ord. ID:

Lab Use Only
Sample Comment
 Preservation non-performance identified for sample.

Customer Sample ID	Matrix *	Comp / Grab	Collected		Res. CL2	Number & Type of Containers	Field Filtered (if applicable): [] Yes [] No	Analysis:
			Date	Time				
210	DW	G	6/12/24	549		1		
211			6/12/24	549				
212			6/12/24	556				
216			6/12/24	600				
217			6/12/24	602				
218			6/12/24	603				
219			6/12/24	603				
220			6/12/24	606				
221			6/12/24	608				
222			6/12/24	606				

Additional Instructions from Pace®:
 # Coolers: 14711 -01 Correction Factor (C): 20.6
 Tracking Number:
 Date/Time: 6/13 9:15
 Date/Time: 6/13 4:10
 Date/Time: 6/13/24 8:00

Collected By: Richard Paszkiewicz
Signature: [Signature]
Received by/Company (Signature): [Signature] 6/12/24
Received by/Company (Signature): [Signature] 6/12/24
Received by/Company (Signature): [Signature] 6/13 8:00

Customer Remarks / Special Conditions / Possible Hazards:
 Lead

Delivered by: [] In-Person [X] Courier
 [] FedEx [] UPS [] Other
 Page: 3 of 5

Company Name: Intertek-PSI
Street Address: 17 British American Blvd, Latham, NY 12120
Customer Project #: 08215496
Project Name: Bethlehem CSD
 Site Collection Info/Facility ID (as applicable): High School

Contact/Report To: William Kotas
 Phone #: (518) 377-9841
 E-Mail: william.kotas@intertek.com
 Cc E-Mail:
Invoice To: PSI Latham Accounts Payable
 Invoice E-Mail: LathamAR@intertek.com
 Purchase Order # (if applicable):
 Quote #: CR-BOCES

County / State origin of sample(s): New York
 Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW
Rush (Pre-approval required): DW PWSID # or WW Permit # as applicable:
 [] 12 Day [] 3 day [] 5 day [] Other: Standard 10 business day
 Date Results Requested:
 Field Filtered (if applicable): [] Yes [] No
 Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected		Composite End		Res. CL2	Number & Type of Containers		Preservation non-compliance identified for sample.
			Date	Time	Date	Time		Plastic	Glass	
223	DW	G	6/12/24	607				1		
224			6/12/24	607						
225			6/12/24	609						
226			6/12/24	610						
231			6/12/24	641						
232			6/12/24	624						
233			6/12/24	629						
234			6/12/24	632						
235			6/12/24	633						
236			6/12/24	620						

Customer Remarks / Special Conditions / Possible Hazards:

Lead

Collected By: Richard Paszkiewicz
 Signature: *Richard Paszkiewicz*

Relinquished by/Company: (Signature) Date/Time: 6/12/24 9:15
 Signature: *Chm Janina*

Relinquished by/Company: (Signature) Date/Time: 6-12-24 9:22
 Signature: *Paula Spore*

Relinquished by/Company: (Signature) Date/Time: 6/13 8:00
 Signature: *WAL*

Relinquished by/Company: (Signature) Date/Time: 6/13/24 8:00
 Signature: *PACOM*

Received by/Company: (Signature) Date/Time: 6-12-24
 Signature: *Chm Janina*

Received by/Company: (Signature) Date/Time: 6/13/24 8:00
 Signature: *PACOM*

Received by/Company: (Signature) Date/Time: 6/13/24 8:00
 Signature: *PACOM*

Additional Instructions from Pace*:
 # Coolers: 1 Thermometer ID: 17724 Correction Factor (°C): -0.1 Obs Temp (°C): 20.6 Corrected Temp (°C): 20.6
 Date/Time: 9:15 Tracking Number:
 Date/Time: 6/13 4:51 Delivered by: [] In-Person [] Courier
 Date/Time: 6/13/24 8:00 [] FedEx [] UPS [] Other
 Page: 4 of 5

LAB USE ONLY - Affix Workorder/Login Label Here



Scan QR Code for instructions

Specify Container Size **
 Identify Container Preservative Type **
 Analysis Requested

Proj. Mgr: Lori Beyer
 AcctNum / Client ID:
 Table #:
 Profile / Template: 10367
 Prelog / Bottle Ord. ID:

Lab Use Only
 Sample Comment



LAB USE ONLY - Affix Workorder/Login Label Here

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Scan QR Code for instructions

Pace
Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

Company Name: Intertek-PSI
Street Address: 17 British American Blvd, Latham, NY 12120

Customer Project #: 08215496
Project Name: Bethlehem CSD

Contact/Report To: William Kotas
Phone #: (518) 377-9841
E-Mail: william.kotas@intertek.com
Ct E-Mail:

Invoice To: PSI Latham Accounts Payable
Invoice E-Mail: LathamAR@intertek.com

Purchase Order # (if applicable):
Quote #: CR-BOCES

Specify Container Size **
125mL, (5) 100mL, (6) 40mL Vial, (7) EnCore, (8) TerraCore, (9) Other

Identify Container Preservative Type ***
H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Analysis Requested

Proj. Mgr: Lori Beyer
AcctNum / Client ID:

Table #:
Profile / Template: 10367
Prelog / Bottle Ord. ID:

****Container Size:** (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL Vial, (7) EnCore, (8) TerraCore, (9) Other

***** Preservative Types:** (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only

Preservation non-conformance identified for sample:

200.8 Drinking Water (Pb only)

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Composite End	Res. CL2	Number & Type of Containers	
			Date	Time			Date	Time
237	DW	G	6/12/24	6:21			1	1
238			6/12/24	6:37				
241			6/12/24	5:41				

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
[] 2 Day [] 3 day [] 5 day [] Other

Date Results Requested: Standard 10 business day

Field Filtered (if applicable): [] Yes [] No

Analysis:

County / State origin of sample(s): New York

*** Matrix Codes (Insert in Matrix box below):** Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Additional Instructions from Pace:

Collected By: Richard Paszkiewicz
Signature: *[Signature]*

Received by/Company (Signature): *[Signature]*
Date/Time: 6/12/24 9:15

Received by/Company (Signature): *[Signature]*
Date/Time: 6/12/24 9:22

Received by/Company (Signature): *[Signature]*
Date/Time: 6/13/24 8:00

Received by/Company (Signature): *[Signature]*
Date/Time: 6/13/24 8:00

Thermometer ID: T-001
Correction Factor (°C): -0.1
Obs. Temp. (°C): 20.6
Corrected Temp. (°C): 20.5

Tracking Number:

Date/Time: 6/12/24 9:15

Date/Time: 6/12/24 4:51

Date/Time: 6/13/24 8:00

Date/Time: 6/13/24 8:00

Delivered by: [] In-Person [] Courier
[] FedEx [] UPS [] Other

Page: 5 of 5

Customer Remarks / Special Conditions / Possible Hazards:

Lead

Relinquished by/Company (Signature): *[Signature]*
Date/Time: 6/12/24 9:15

Relinquished by/Company (Signature): *[Signature]*
Date/Time: 6/12/24 9:22

Relinquished by/Company (Signature): *[Signature]*
Date/Time: 6/13/24 8:00

Relinquished by/Company (Signature): *[Signature]*
Date/Time: 6/13/24 8:00

10367

Client: Inter-Latham

Profile #:

Work ID: P Benlatham OSD612 -COC Page

Use Point Number Spreadsheet

Add SCLOGFD to first sample for field charge

Multiday Project

of _____

COC Line Item	Matrix	Container	Quantity	Material	Notes
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					

WO#: 70301179
PM: LAB
CLIENT: INTER-LATHAM
Due Date: 06/26/24

Container	Matrix	Quantity	Material	Notes
VG9J	40mL unpres. clear glass	125mL	unpres. amber glass	
VG9C	40mL Ascorbic-HCl clear vial	AG4U	250mL unpres. amber glass	
VG9H	40mL HCl clear vial	AG3U	250mL unpres. amber glass	
VG9S	40mL Sulfuric clear vial	AG2U	500mL unpres. amber glass	
VG9T	40mL Na Thiosulfate vial	AG1U	1L unpres. amber glass	
DG9Y	40mL Citrate-Na Thiosulfate	AG34	Ammonium Cl 250mL bottle	
DG9P	40mL amber vial - TSP	AG3S	250mL H2SO4 amber glass	
DG9A	Ascorbic/Maleic Acid 40mL	AG4E	125mL EDA amber glass	
DG9S	Na Thio 60mL Vial	AG3T	250mL Na Thio amber glass	
DG6T	Ammonium Cl/CuSO4 40mL	AG2R	Na Sulfite 500mL (blue Cap)	
CG1U	1L Unpres Jar (Con Est)	AG1T	Na Thiosulfate 1L bottle	
WG90	4oz clear soil jar	AG1H	1L HCl amber glass	
WG40	4oz clear soil jar	AG1A	1L Ammonium Chloride	
		AG5U	100mL unpres Amber Glass	
		AG44	Ammonium Cl 120mL bottle	
		BP4U	125mL unpres. plastic	
		BP3U	250mL unpres. plastic	
		BP2U	500mL unpres. plastic	
		BP1U	1L unpres. plastic	
		BP4N	125mL HNO3 plastic	
		BP3N	250mL HNO3 plastic	
		BP2N	500mL HNO3 plastic	
		BP3S	250mL H2SO4 plastic	
		BP2S	500mL H2SO4 plastic	
		BP3C	NaOH 250mL bottle	
		BP3T	250mL Trizma	
		BP3S	250mL Ammonium Acetate	
		BP3R	250mL NH4SO4-NH4OH	
		BP1Z	1L NaOH, Zn Acetate	
		BP1N	1L HNO3 plastic	
		BP1B	Na Thiosulfate Amber Bottle	

WT	Matrix
SL	Water
NAL	Solid
OL	Non-aqueous Liquid
WP	OIL
DW	Wipe
	Drinking Water

BP1U	IOC
BP3N*	1L unpreserved plastic
BP3C	250mL HNO3 plastic
AG2U	500mL Sodium Hydroxide
BP3U	500mL unpres amber glass
	250mL unpreserved plastic

* Can also be a BP4N

SP5T	Misc.
R	120mL Collform Na Thio
WG2U	Terracone Kit
WG3U	2oz Unpreserved Jar
WG4U	4oz Unpreserved Jar
WG5U	8oz Unpreserved Jar
WG6U	16oz Unpreserved Jar
ZPLC	Ziplock Bag
TEDL	Tedlar Bag
GN	1L HCl Clear Glass
GN	General
WP	Wipe
LLHG	Low Level Hg Bottles
BGIN	1L HNO3 Clear Glass

VG9T	SOC
DG9A	40mL Na Thio amber vial
DG9Y	40mL Ascorbic acid makes Acid salts
DG6T	Citrate/Na Thiosulfate 40mL
DG6M	Na Thiosulfate 60mL vial
AG3U	MonoChloric/Na Thio 60mL
AG3T	250mL unpres. amber glass
BP1B	Na Thiosulfate 250mL bottle
AG1T	Na Thiosulfate 1L Amber
AG1A	525.3 Chemical Blend

Sender Initials: AD

Additional Comments

DC#_Title: Excel Form Template
 Effective Date:

WO#: 70301179
PM: LAB Due Date: 06/26/24
CLIENT: INTER-LATHAM

Client Name: Inter-Latham Project:

Courier: Fed Ex UPS USPS Client Commercial Pac Other

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No
 Packing Material: Bubble Wrap Bubble Bags Ziploc None Other Type of Ice: Mel Blue None

Thermometer Used: TN211 Correction Factor: -0.1 Samples on ice, cooling process has begun
 Cooler Temperature(°C): 20.6 Cooler Temperature Corrected(°C): 20.5 Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: wk 6/13/24

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: <input checked="" type="checkbox"/> SL <input type="checkbox"/> WT <input type="checkbox"/> OIL <input type="checkbox"/> OTHER	

Date and Initials of person checking preservation: ADD 6/13/24

All containers needing preservation have been <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>200623</u>	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH>12 Cyanide)	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #	
Residual chlorine strips Lot #	15. Positive for Sulfide? Y N
SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Lead Acetate Strips Lot #	
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.